

NextEra Energy Canada Jericho Wind Energy Centre

Community Liaison Committee (CLC): Meeting #4

March 9, 2016

6:00 p.m. to 8:00 p.m.

The Legacy Recreation Centre

16 Allen Street, Thedford

NOTE: This meeting package was compiled by the CLC Coordinators and Facilitators (AECOM) and as such may be subject to clarification or correction by NextEra Energy Canada and its technical staff/specialists. The CLC members will be notified of any revisions to the meeting package, and the final package will be posted and available for public review on NextEra Energy Canada's website.



Introductions

CLC Members:

- Carol Clay
- John Couwenberg
- Dean Jacobs
- Marilyn Keunecke-Smith
- Mary Lynn Metras
- John Moons
- Marina Plain
- Jamie Tabor
- Eddy Van Engelen

CLC Coordinators and Facilitators (AECOM):

- Adam Wright
- Tiffany Lobb

NextEra Energy Canada:

- Julie Rice, Business Management
- Amanda Gittens, Business Management
- Peter Miller, Wind Site Manager
- Derek Dudek, PGD Sr. Technical Services Manager
- Heidi Lamarche, Construction

Consultants

- Charlotte Teat, Biologist, Natural Resource Solutions, Inc.

Agenda

1. Introductions

2. Recap of CLC Meeting #3

- Purpose of the CLC
- Overview of the Project
- Post-Construction Activities
- Operations and Maintenance Update and Activities
- Public Attendance and Depositions
- Meeting Summary

3. Parking Lot Items and Questions / Comments Raised Since the Third CLC Meeting

4. Update on Construction and Remediation Efforts

5. Update from the Operations Team

6. Delegations – none received

7. Public Question and Answer

Recap: CLC Meeting #3

Meeting Summary for our 3rd CLC Meeting:

- Draft minutes were prepared by AECOM and circulated to the CLC on **Dec. 17, 2015**
- Members were asked to advise AECOM of any errors, omissions or changes by **Jan. 4, 2016**
- All recommended comments/changes were incorporated and the minutes were posted on NextEra's publically accessible website the week of **Jan. 11, 2016**
- CLC members were also emailed the final minutes on **Jan. 8, 2016**

Activities and Questions/Comments Raised Since CLC #3

Parking Lot Topic	Response / Action
<p>No parking lot issues were identified at the third CLC meeting</p>	

Recap CLC Meeting #3 – Local Labour

Construction Stats

- General Contractor is Borea Construction Canada
- Many **Southwestern Ontario Companies** used (subcontractors and suppliers) on the Jericho project.
- There is at least **\$6 million** in contracts with subcontractors and suppliers in the southwestern Ontario region. Services ranging from materials, equipment, utilities, labour, housing, and subcontractors, were provided by nearly 30 Lambton and Middlesex County businesses.
- Peak volume of individuals on site including subcontractors is approximately 200.
- Indirect economic benefits have not been measured, but local hotels, restaurants, home improvement stores, gas stations, machine shops, pubs and grocery stores have seen an increase in business since the start of the project.

Projected Economic Impact

Construction Jobs:	Approx. 200
Full Time Jobs:	10
Capital Expenditures	Over \$400 Million
Corporate Income Tax	Over \$200 Million*
Property Taxes:	Over \$8 Million*
Landowner Payments:	About \$30 Million*

Performance

Performance is exceeding expectations – Equivalent Forced Outage Rate Year-to-Date is .63%
Excellent safety performance – 0 lost-time injuries

*Estimated over first 20 years of the project.

Update on Construction and Remediation Efforts

1) Construction Clean up, Modifications and Road Repairs: largely complete

- NextEra is complete with its physical restoration work but has an agreement in place with Lambton Shores and Warwick to pay for the restoration of key roads that were used during construction.
- While we do not have a Road Use Agreement with Lambton County, we are continuing to restore county roads.
- Additionally, we have hired an engineering firm to inspect all ditches or rights of way (ROW) for any outstanding reclaim items due to underground collection installation and all mitigation measures installed along the transmission line.

2) Reclamation: Summer to Fall 2015

- Stripped soil was replaced and re-contoured in the construction areas and disturbed areas reseeded during appropriate conditions for germination (as seasonality allows).

Operations – Complaint Resolution:

- NextEra acknowledges that some members of the community may have concerns regarding wind farm operations.
- To resolve disputes in a collaborative manner, NextEra follows its complaints resolution process.
- Should any complaints arise throughout the course of the operation and decommissioning phases, a NextEra representative will contact the complainant to understand the nature of the complaint.
- NextEra will **notify the local MOECC** (Ministry of Environment and Climate Change) **district office** of the complaint **within 2 business days** of receipt of the complaint (**1 business day** if the complaint is related to **Ground Water**).
- NextEra will provide the local MOECC district office with a written records of the complaint **within 8 business days** of the complaint. The MOECC notification will include:
 - Description of the nature of the complaint;
 - Wind direction at the time of the incident related to the complaint;
 - Time and date of the incident related to the complaint; and
 - A description of the measures taken to address the cause of the incident and to prevent a similar occurrence in the future.

Operations – Complaint Resolution, cont'd:

- Upon resolution of complaint, verbal and written correspondence will be provided to complainant as soon as possible.
- Information requests and complaints about the Jericho project specifically:
NextEra Energy Canada, LP
390 Bay Street, Suite 1720
Toronto, ON M5H 2Y2
Toll Free Phone: 1-877-463-4963
Email: jericho.wind@nexteraenergy.com
Website: www.NextEraEnergyCanada.com
- Any other general inquiries to NextEra Energy Canada, LP:
416-364-9714 - Main
877-257-7330 - Toll Free

Monitoring and Mitigation Measures

- **Environmental Effects Monitoring Plan**

- In accordance with the requirements of Ontario Regulation (O.Reg.) 359/09, the Environmental Effects Monitoring Plan addresses various elements including, but not limited to, heritage and archaeological resources, natural heritage features and noise.

- **Noise**

- The Provincial Environmental Protection Act (EPA) requires that noise emissions for any new projects must not have any adverse effects on the natural environment and not exceed 40dBA when wind speeds are of 6 metres/second and below.

NOTE: the allowable noise levels increase during higher wind speeds.

- Prior to construction, a Renewable Energy Approval (REA) was obtained with measures to be adhered to, i.e. noise modeling by independent consultants.
- Noise emissions will not likely change unless there is damage to the equipment (immediately recognized by the computer monitoring system and addressed by the operations team).
- Acoustic Emission and Immission testing is partly completed. Results will be reported to the MOECC in late spring 2016.

Monitoring and Mitigation Measures

- **Bird and Bat Post-Construction Monitoring**

- Monitoring will be conducted in accordance with requirements of the REA and Ministry of Natural Resources and Forestry (MNR) Guidelines
- Monitoring began May 1, 2015
- Turbine searches occurred twice weekly from May 1st through October 31st, and raptor surveys continued weekly from November 1st through November 30th.
- Correction factors are applied in order to calculate overall estimated mortality rates across the project
- Annual report provided to MNR by end of February following each year of monitoring
- 3 years of monitoring are required

- **Species-At-Risk (SAR) Monitoring**

- Species at Risk mortality monitoring began in April 2015
- Monitoring has been conducted in accordance with MNR requirements
- All 92 turbines were searched monthly between April and November
- Annual report completed
- Species at Risk Monitoring continues for the life of the project

Monitoring and Mitigation Measures

- **Natural Heritage Monitoring**

- Post construction monitoring of certain wildlife habitats is required by the REA
- Amphibian Breeding and Red-headed Woodpecker Habitat Monitoring
- Bat maternity colony habitat
- Habitat monitoring began in 2015, in accordance with the requirements of the REA
- 3 Years of habitat monitoring is required
- Annual reports will be submitted to MNRF by March 31 of each year of monitoring



Retirement and Decommissioning

Lifespan

- The average lifespan of a turbine is 25 years.
- At the end of its lifecycle, a wind facility can either be decommissioned or repowered.

Repowering

- If the economics are viable, a facility may be repowered with new technology.

Decommissioning

- The process and impacts are similar to the construction phase, but in reverse sequence

Decommissioned Equipment Left in Place:

- Underground electrical lines will be cut and the ends buried 1m below grade. These lines are inert and will have no negative impacts on the environment, soil and cultivation practices.
- Foundations will be left in place. The top 1m will be removed and replaced with clean fill and stockpiled topsoil – to allow for cultivation of agricultural lands.

Recycling

- All materials will be recycled, where possible, or disposed offsite at an approved and appropriate facility.

Public - Question and Answer Period



Thank you!



NextEra Energy Canada and AECOM would like to sincerely thank all the CLC members for donating their time over the past two years and for their valuable input and interest in the project.